



<http://www.diva-portal.org>

Postprint

This is the accepted version of a paper published in *IEEE Transactions on Control of Network Systems*. This paper has been peer-reviewed but does not include the final publisher proof-corrections or journal pagination.

Citation for the original published paper (version of record):

Andreasson, M., Dimarogonas, D., Sandberg, H., Johansson, K. [Year unknown!]
Distributed Controllers for Multi-Terminal HVDC Transmission Systems.
IEEE Transactions on Control of Network Systems

Access to the published version may require subscription.

N.B. When citing this work, cite the original published paper.

Permanent link to this version:

<http://urn.kb.se/resolve?urn=urn:nbn:se:kth:diva-164311>

Distributed Controllers for Multi-Terminal HVDC Transmission Systems

Martin Andreasson^{*}, Dimos V. Dimarogonas, Henrik Sandberg and Karl H. Johansson
ACCESS Linnaeus Centre, KTH Royal Institute of Technology, Stockholm, Sweden.

Abstract—High-voltage direct current (HVDC) is an increasingly commonly used technology for long-distance electric power transmission, mainly due to its low resistive losses. In this paper the voltage-droop method (VDM) is reviewed, and three novel distributed controllers for multi-terminal HVDC (MTDC) transmission systems are proposed. Sufficient conditions for when the proposed controllers render the equilibrium of the closed-loop system asymptotically stable are provided. These conditions give insight into suitable controller architecture, e.g., that the communication graph should be identical with the graph of the MTDC system, including edge weights. Provided that the equilibria of the closed-loop systems are asymptotically stable, it is shown that the voltages asymptotically converge to within predefined bounds. Furthermore, a quadratic cost of the injected currents is asymptotically minimized. The proposed controllers are evaluated on a four-bus MTDC system.

I. INTRODUCTION

The transmission of power over long distances is one of the greatest challenges in today's power transmission systems. Since resistive losses increase with the length of power transmission lines, higher voltages have become abundant in long-distance power transmission. One example of long-distance power transmission are large-scale off-shore wind farms, which often require power to be transmitted in cables over long distances to the mainland AC power grid. High-voltage direct current (HVDC) power transmission is a commonly used technology for long-distance power transmission. Its higher investment costs compared to AC transmission lines, mainly due to expensive AC-DC converters, are compensated by its lower resistive losses for sufficiently long distances [8]. The break-even point, i.e., the point where the total costs of overhead HVDC and AC lines are equal, is typically 500-800 km [21]. However, for cables, the break-even point is typically lower than 100 km, due to the AC current needed to charge the capacitors of the cable insulation [7]. Increased use of HVDC for electrical power transmission suggests that future HVDC transmission systems are likely to consist of multiple terminals connected by several HVDC transmission lines. Such systems are referred to as multi-terminal HVDC (MTDC) systems in the literature [25].

This work was supported in part by the European Commission by the Swedish Research Council and the Knut and Alice Wallenberg Foundation. The 2nd author is also affiliated with the Centre for Autonomous Systems at KTH. This work extends the manuscripts presented in [5], [2]. The Authors are with the ACCESS Linnaeus Centre, KTH Royal Institute of Technology, 11428 Stockholm, Sweden. ^{*} Corresponding author. E-mail: mandreas@kth.se

Maintaining an adequate DC voltage is an important control problem for HVDC transmission systems. Firstly, the voltage levels at the DC terminals govern the current flows by Ohm's law and Kirchhoff's circuit laws. Secondly, if the DC voltage deviates too far from a nominal operational voltage, equipment may be damaged, resulting in loss of power transmission capability [25]. For existing point-to-point HVDC connections consisting of only two buses, the voltage is typically controlled at one of the buses, while the injected current is controlled at the other bus [15]. As this decentralized controller structure has no natural extension to the case with three or more buses, various methods have been proposed for controlling MTDC systems. The voltage margin method, VMM, is an extension of the controller structure of point-to-point connections. For an n -bus MTDC system, $n - 1$ buses are assigned to control the injected current levels around a setpoint, while the remaining bus controls the voltage around a given setpoint. VMM typically controls the voltage fast and accurately. The major disadvantage is the undesirable operation points, which can arise when one bus alone has to change its current injections to maintain a constant voltage level. While this can be addressed by assigning more than one bus to control the voltage, it often leads to undesirable switching of the injected currents [19]. The voltage droop method, VDM, on the other hand is symmetric, in the sense that all local decentralized controllers have the same structure. Each bus injects current at a rate proportional to the local deviation of the bus voltage from its nominal value. Similar to VMM, VDM is a simple decentralized controller not relying on any communication [12], [13]. As we will formally show in this paper, a major disadvantage of VDM is static errors of the voltage, as well as possibly suboptimal operation points.

The highlighted drawbacks of existing decentralized MTDC controllers give rise to the question if performance can be increased by allowing for communication between buses. Distributed controllers have been successfully applied to both primary, secondary, and to some extent also tertiary frequency control of AC transmission systems [3], [24], [16], [4], [18]. Although the dynamics of HVDC grids can be modelled with a lower order model than AC grids, controlling DC grids may prove more challenging. This is especially true for decentralized and distributed controller structures. The challenges consist of the faster time-scales of MTDC systems, as well as the lack of a globally measurable

variable corresponding to the AC frequency. In [9], [10], [23], [6], decentralized controllers are employed to share primary frequency control reserves of AC systems connected through an MTDC system. Due to the lack of a communication network, the controllers induce static control errors. In [22], a distributed approach is taken in contrast to the previous references, allowing for communication between DC buses and thus improving the performance of the controller. In [1], [17], distributed voltage controllers for DC microgrids achieving current sharing are proposed. The controllers however relies on a complete communication network. In [20], a distributed controller for DC microgrids with an arbitrary, connected communication network is proposed. Stability of the closed-loop system is however not guaranteed.

In this paper three novel distributed controllers for MTDC transmission systems are proposed, all allowing for certain limited communication between buses. It is shown that under certain conditions, the proposed controllers render the equilibrium of the closed-loop system asymptotically stable. Additionally the voltages converge close to their nominal values, while a quadratic cost function of the current injections is asymptotically minimized. The sufficient stability criteria derived in this paper give insights into suitable controller architecture, as well as insight into the controller design. All proposed controllers are evaluated by simulation on a four-bus MTDC system.

The remainder of this paper is organized as follows. In Section II, the mathematical notation is defined. In Section III, the system model and the control objectives are defined. In Section IV, some generic properties of MTDC systems are derived. In Section V, voltage droop control is analyzed. In Section VI, three different distributed averaging controllers are presented, and their stability and steady-state properties are analyzed. In Section VII, simulations of the distributed controllers on a four-terminal MTDC system are provided, showing the effectiveness of the proposed controllers. The paper ends with a concluding discussion in Section VIII.

II. NOTATION

Let \mathcal{G} be a graph. Denote by $\mathcal{V} = \{1, \dots, n\}$ the vertex set of \mathcal{G} , and by $\mathcal{E} = \{1, \dots, m\}$ the edge set of \mathcal{G} . Let \mathcal{N}_i be the set of neighboring vertices to $i \in \mathcal{V}$. In this paper we will only consider static, undirected and connected graphs. For the application of control of MTDC power transmission systems, this is a reasonable assumption as long as there are no power line failures. Denote by \mathcal{B} the vertex-edge adjacency matrix of a graph, and let $\mathcal{L}_{\mathcal{W}} = \mathcal{B}\mathcal{W}\mathcal{B}^T$ be its weighted Laplacian matrix, with edge-weights given by the elements of the positive definite diagonal matrix \mathcal{W} . Let \mathbb{C}^- denote the open left half complex plane, and $\bar{\mathbb{C}}^-$ its closure. We denote by $c_{n \times m}$ a matrix of dimension $n \times m$ whose elements are all equal to c , and by c_n a column vector whose elements are all equal to c . For a symmetric matrix A , $A > 0$ ($A \geq 0$) is used to denote that A is positive (semi) definite. I_n denotes the identity matrix of dimension n . For vectors x and y , we denote by $x \leq y$ that the inequality holds for all elements. We will often drop the notion of

time dependence of variables, i.e., $x(t)$ will be denoted x for simplicity.

III. MODEL AND PROBLEM SETUP

Consider an MTDC transmission system consisting of n HVDC terminals, henceforth referred to as buses. The buses are denoted by the vertex set $\mathcal{V} = \{1, \dots, n\}$, see Figure ?? for an example of an MTDC topology. The DC buses are modelled as ideal current sources which are connected by m HVDC transmission lines, denoted by the edge set $\mathcal{E} = \{1, \dots, m\}$. The dynamics of any system (e.g., an AC transmission system) connected through the DC buses, or any dynamics of the DC buses (e.g., AC-DC converters) are neglected. The HVDC lines are assumed to be purely resistive, neglecting capacitive and inductive elements of the HVDC lines. The assumption of purely resistive lines is not restrictive for the control applications considered in this paper [15]. This implies that

$$I_{ij} = \frac{1}{R_{ij}}(V_i - V_j),$$

due to Ohm's law, where V_i is the voltage of bus i , R_{ij} is the resistance and I_{ij} is the current of the HVDC line from bus i to j . The voltage dynamics of an arbitrary DC bus i are thus given by

$$\begin{aligned} C_i \dot{V}_i &= - \sum_{j \in \mathcal{N}_i} I_{ij} + I_i^{\text{inj}} + u_i \\ &= - \sum_{j \in \mathcal{N}_i} \frac{1}{R_{ij}}(V_i - V_j) + I_i^{\text{inj}} + u_i, \end{aligned} \quad (1)$$

where C_i is the total capacitance of bus i , including shunt capacitances and the capacitance of the HVDC line, I_i^{inj} is the nominal injected current, which is assumed to be unknown but constant over time, and u_i is the controlled injected current. Note that we impose no dynamics nor constraints on the controlled injected current u_i . In practice, this requires that each MTDC bus is connected with a strong AC grid which can supply sufficient power to the MTDC grid. Equation (1) may be written in vector-form as

$$C \dot{V} = -\mathcal{L}_R V + I^{\text{inj}} + u, \quad (2)$$


where $V = [V_1, \dots, V_n]^T$, $C = \text{diag}([C_1, \dots, C_n])$, $I^{\text{inj}} = [I_1^{\text{inj}}, \dots, I_n^{\text{inj}}]^T$, $u = [u_1, \dots, u_n]^T$ and \mathcal{L}_R is the weighted Laplacian matrix of the graph representing the transmission lines, whose edge-weights are given by the conductances $\frac{1}{R_{ij}}$. For convenience, we also introduce the matrix of elastances $E = \text{diag}([C_1^{-1}, \dots, C_n^{-1}])$. The control objective considered in this paper is defined below.

Objective 1. *The cost of the current injections should be minimized asymptotically. More precisely*

$$\lim_{t \rightarrow \infty} u(t) = u^*, \quad (3)$$

where u^* is defined by

$$[u^*, V^*] = \underset{[u, V]}{\text{argmin}} \sum_{i \in \mathcal{V}} \frac{1}{2} f_i u_i^2 \quad \text{s.t.} \quad \mathcal{L}_R V = I^{\text{inj}} + u, \quad (4)$$



and where $f_i > 0, i = 1, \dots, n$, are any positive constants. Furthermore the following quadratic cost function of the voltage deviations should be minimized:

$$\sum_{i \in \mathcal{V}} \frac{1}{2} g_i (V_i^{nom} - V_i)^2, \quad (5)$$

for some $g_i \geq 0 \forall i = 1, \dots, n$, and V_i^{nom} is the nominal voltage of bus i .

Remark 1. Equations (3)–(4) imply that the asymptotic voltage differences between the DC buses are bounded, i.e., $\lim_{t \rightarrow \infty} |V_i(t) - V_j(t)| \leq \Delta V \forall i, j \in \mathcal{V}$, for some $\Delta V > 0$. This implies that it is in general not possible to have $\lim_{t \rightarrow \infty} V_i(t) = V_i^{nom}$ for all $i \in \mathcal{V}$, e.g., by PI-control. We show in Lemma 1 that ΔV can be bounded by a function of the injected and controlled injected currents, $I^{inj} + u$, as well as the Laplacian matrix of the MTDC system.

Remark 2. The optimal solution V^* of (3)–(4) is unique only up to an additive constant vector c_n , where all elements are equal. Minimizing (5) determines this constant vector, which can be seen as the average voltage in the MTDC grid.

Remark 3. Equations (3)–(4) are analogous to the quadratic optimization of AC power generation costs, c.f., [3], [11]. The quadratic cost function of the voltages (5) has no analogy in the corresponding secondary AC frequency control problem. This since the voltages in an MTDC grid do not synchronize in general, as opposed to the frequencies in an AC grid.

IV. GENERAL PROPERTIES OF MTDC SYSTEMS

Before exploring different control strategies for MTDC systems, we derive some general results on properties of controlled MTDC systems which will be useful for the remainder of this paper. Our first result gives a generic upper

bound on the asymptotic relative voltage differences of an MTDC system, regardless of the controller structure.

Lemma 1. Consider any stationary control signal u . The relative voltage differences satisfy

$$|V_i - V_j| \leq 2I^{max} \sum_{i=2}^n \frac{1}{\lambda_i},$$

where $I^{max} = \max_i |I_i^{tot}|$ and $I_i^{tot} = I_i^{inj} + u_i$ and λ_i denotes the i 'th eigenvalue of \mathcal{L}_R .

Proof. Consider the equilibrium of (2):

$$\mathcal{L}_R V = I^{inj} + u \triangleq I^{tot}. \quad (6)$$

Let $V = \sum_{i=1}^n a_i w_i$, where w_i is the i 'th eigenvector of \mathcal{L}_R with the corresponding eigenvalue λ_i . Since \mathcal{L}_R is symmetric, the eigenvectors $\{w_i\}_{i=1}^n$ can be chosen so that they form an orthonormal basis of \mathbb{R}^n . Using the eigendecomposition of V above, we obtain the following equation from (6):

$$\mathcal{L}_R V = \mathcal{L}_R \sum_{i=1}^n a_i w_i = \sum_{i=1}^n a_i \lambda_i w_i = I^{tot}. \quad (7)$$

By premultiplying (7) with w_k for $k = 1, \dots, n$, we obtain:

$$a_k \lambda_k = w_k^T I^{tot},$$

due to orthonormality of $\{w_i\}_{i=1}^n$. Hence, for $k = 2, \dots, n$ we get

$$a_k = \frac{w_k^T I^{tot}}{\lambda_k}.$$

The constant a_1 is not determined by (7), since $\lambda_1 = 0$. Denote $\Delta V = \sum_{i=2}^n a_i w_i$. Since $w_1 = \frac{1}{\sqrt{n}} \mathbf{1}_n$, $V_i - V_j = \Delta V_i - \Delta V_j$ for any $i, j \in \mathcal{V}$. Thus, the following bound is easily obtained:

$$\begin{aligned} |V_i - V_j| &= |\Delta V_i - \Delta V_j| \leq 2 \max_i |\Delta V_i| = 2 \|\Delta V\|_\infty \\ &\leq 2 \|\Delta V\|_2 = 2 \left\| \sum_{i=2}^n a_i w_i \right\|_2 \leq 2 \sum_{i=2}^n |a_i| = 2 \sum_{i=2}^n \left| \frac{w_i^T I^{tot}}{\lambda_i} \right| \\ &\leq 2I^{max} \sum_{i=2}^n \frac{1}{\lambda_i}, \end{aligned}$$

where we have used the fact that $\|w_i\|_2 = 1$ for all $i = 1, \dots, n$, and $\|x\|_\infty \leq \|x\|_2$ for any $x \in \mathbb{R}^n$. \square

Our second result reveals an interesting general structure of asymptotically optimal MTDC control signals.

Lemma 2. Equations (3)–(4) in Objective 1 are satisfied if and only if $\lim_{t \rightarrow \infty} u(t) = \mu F^{-1} \mathbf{1}_n$ and $\lim_{t \rightarrow \infty} \mathcal{L}_R V(t) = I^{inj} + \mu F^{-1} \mathbf{1}_n$, where $F = \text{diag}([f_1, \dots, f_n])$. The scaling factor is given by $\mu = -(\sum_{i=1}^n I_i^{inj}) / (\sum_{i=1}^n f_i^{-1})$.

Proof. The KKT condition for the optimization problem (4) is $Fu = \mu \mathbf{1}_n$, which gives $u = F^{-1} \mu \mathbf{1}_n$. Substituting this expression for u and pre-multiplying the constraint $\lim_{t \rightarrow \infty} \mathcal{L}_R V(t) = I^{inj} + F^{-1} \lambda \mathbf{1}_n$ with $\mathbf{1}_n^T$, yields the desired expression for μ . Since (4) is convex, the KKT condition is a necessary and sufficient condition for optimality. \square

Lemma 3. Equation (5) in Objective 1 is minimized if and only if $\sum_{i=1}^n g_i(V_i - V_i^{\text{nom}}) = 0$.

Proof. By considering the equilibrium of (2), the relative voltages ΔV are uniquely determined by I^{inj} and u . Thus $V = \Delta V + k\mathbf{1}_n$, for some $k \in \mathbb{R}$. Taking the derivative of the quadratic cost function (5) with respect to k thus corresponds to the necessary and sufficient KKT condition for optimality, and yields:

$$\frac{\partial}{\partial k} \sum_{i \in \mathcal{V}} \frac{1}{2} g_i (V_i^{\text{nom}} - V_i)^2 = \sum_{i=1}^n g_i (V_i - V_i^{\text{nom}}) = 0.$$

□

Remark 4. The choice of the controller gains as detailed in Lemma 2, is analogous to the controller gains in the AC frequency controller being inverse proportional to the coefficients of the quadratic generation cost function [11].

V. VOLTAGE DROOP CONTROL

In this section the VDM will be studied, as well as some of its limitations. VDM is a simple decentralized proportional controller taking the form

$$u_i = K_i^P (V_i^{\text{nom}} - V_i), \quad (\text{VDM})$$

where V^{nom} is the nominal DC voltage. Alternatively, the controller (VDM) can be written in vector form as

$$u = K^P (V^{\text{nom}} - V), \quad (8)$$

where $V^{\text{nom}} = [V_1^{\text{nom}}, \dots, V_n^{\text{nom}}]^T$ and $K^P = \text{diag}([K_1^P, \dots, K_n^P])$. The decentralized structure of the voltage droop controller is often advantageous for control of HVDC buses, as the time constant of the voltage dynamics is typically smaller than the communication delays between the buses. The DC voltage regulation is typically carried out by all buses. However, VDM possesses some severe drawbacks. Firstly, the voltages of the buses don't converge to a value close to the nominal voltages in general. Secondly, the controlled injected currents do not converge to the optimal value.

Theorem 4. Consider an MTDC network described by (1), where the control input u_i is given by (VDM) and the injected currents I_i^{inj} are constant. The equilibrium of the closed-loop system is stable for any $K^P > 0$, in the sense that the voltages V converge to some constant value. In general, Objective 1 is not satisfied. However, the controlled injected currents satisfy $\lim_{t \rightarrow \infty} \sum_{i=1}^n (u^i + I_i^{\text{inj}}) = 0$.

Proof. The closed-loop dynamics of (2) with u given by (VDM) are

$$\begin{aligned} \dot{V} &= -E\mathcal{L}_R V + EK^P (V^{\text{nom}} - V) + EI^{\text{inj}} \\ &= \underbrace{-E(\mathcal{L}_R + K^P)}_{\triangleq A} V + EK^P V^{\text{nom}} + EI^{\text{inj}}. \end{aligned} \quad (9)$$

Clearly the equilibrium of (9) is stable if and only if A as defined above is Hurwitz. Consider the characteristic polynomial of A :

$$\begin{aligned} 0 &= \det(sI_n - A) = \det\left(sI_n + E(\mathcal{L}_R + K^P)\right) \\ \Leftrightarrow 0 &= \det\left(\underbrace{sC + (\mathcal{L}_R + K^P)}_{\triangleq Q(s)}\right). \end{aligned}$$

The equation $0 = \det(Q(s))$ has a solution for a given s only if $0 = x^T Q(s)x$ has a solution for some $\|x\|_2 = 1$. This gives

$$0 = s \underbrace{x^T C x}_{a_1} + \underbrace{x^T (\mathcal{L}_R + K^P) x}_{a_0}.$$

Clearly $a_0, a_1 > 0$, which implies that the above equation has all its solutions $s \in \mathbb{C}^-$ by the Routh-Hurwitz stability criterion. This implies that the solutions of $0 = \det(Q(s))$ satisfy $s \in \mathbb{C}^-$, and thus that A is Hurwitz.

Now consider the equilibrium of (9):

$$0 = -(\mathcal{L}_R + K^P)V + K^P V^{\text{nom}} + I^{\text{inj}}. \quad (10)$$

Since $K^P > 0$ by assumption $(\mathcal{L}_R + K^P)$ is invertible, which implies

$$V = (\mathcal{L}_R + K^P)^{-1} (K^P V^{\text{nom}} + I^{\text{inj}}), \quad (11)$$

which does not satisfy Objective 1, in general. By inserting (11) in (8), it is easily seen that

$$u \neq \lambda F^{-1} \mathbf{1}_n$$

in general. By Lemma 2, Objective 1 is thus in general not satisfied. Premultiplying (10) with $\mathbf{1}_n^T C^{-1}$ yields

$$0 = \mathbf{1}_n^T K^P (V^{\text{nom}} - V) + I^{\text{inj}} = \sum_{i=1}^n (u_i + I_i^{\text{inj}}). \quad \square$$

Next, we construct explicitly a class of droop-controlled MTDC systems for which Objective 1 is never satisfied.

Lemma 5. Consider an MTDC network described by (1), where the control input u_i is given by (VDM) and the injected currents $I_i^{\text{inj}} \neq 0_n$ satisfy either $I_i^{\text{inj}} \leq 0_n$ or $I_i^{\text{inj}} \geq 0_n$, where the inequality is strict for at least one element. Furthermore let $V^{\text{nom}} = v^{\text{nom}} \mathbf{1}_n$. Then Equation (5) in Objective 1 is not minimized, regardless of the system and controller parameters.

Proof. The equilibrium of the closed-loop dynamics is given by

$$(\mathcal{L}_R + K^P)(V - v^{\text{nom}} \mathbf{1}_n) = I^{\text{inj}}. \quad (12)$$

For convenience, define $\bar{V} = V - v^{\text{nom}} \mathbf{1}_n$. Without loss of generality, assume that $I_i^{\text{inj}} \leq 0_n$. By premultiplying (12) with $\mathbf{1}_n^T$, we obtain $\mathbf{1}_n^T K^P \bar{V} < 0$. This implies that for at least one index i_1 , $\bar{V}_{i_1} < 0$. Assume for the sake of contradiction that there exists an index i_2 such that $\bar{V}_{i_2} \geq 0$. We can without

loss of generality assume $\bar{V}_{i_2} \geq \bar{V}_i \forall i \neq i_2$. By considering the i_2 th element of (12), we obtain

$$K_{i_2}^P \bar{V}_{i_2} + \sum_{j \in \mathcal{N}_{i_2}} (\bar{V}_{i_2} - \bar{V}_j) \leq 0.$$

This implies that for at least one $j \in \mathcal{N}_{i_2}$ we have $\bar{V}_j > \bar{V}_{i_2}$, contradicting the assumption that $\bar{V}_{i_2} \geq \bar{V}_i \forall i \neq i_2$. Thus, $\bar{V} < 0$, and (5) in Objective 1 can clearly not be minimized. \square

Generally when tuning the proportional gains K^P , there is a trade-off between the voltage errors and the optimality of the current injections. Low gains K^P will result in closer to optimal current injections, but the voltages will be far from the reference value. On the other hand, having high gains K^P will ensure that the voltages converge close to the nominal voltage, at the expense of large deviations from the optimal current injections u^* . This rule of thumb is formalized in the following theorem.

Theorem 6. Consider an MTDC network described by (1), where the control input u_i is given by (VDM) with positive gains $K_i^P = f_i^{-1}$, and constant injected currents I_i^{inj} . The DC voltages satisfy

$$\begin{aligned} \lim_{K^P \rightarrow \infty} \lim_{t \rightarrow \infty} V(t) &= V^{\text{nom}} \\ \lim_{K^P \rightarrow 0} \lim_{t \rightarrow \infty} V(t) &= \text{sgn} \left(\sum_{i=1}^n I_i^{\text{inj}} \right) \infty \mathbf{1}_n, \end{aligned}$$

while the controlled injected currents satisfy

$$\begin{aligned} \lim_{K^P \rightarrow \infty} \lim_{t \rightarrow \infty} u(t) &= -I^{\text{inj}} \\ \lim_{K^P \rightarrow 0} \lim_{t \rightarrow \infty} u(t) &= u^*, \end{aligned}$$

where the notation means

$$\begin{aligned} K^P \rightarrow \infty &\Leftrightarrow K_i^P \rightarrow \infty \forall i = 1, \dots, n \\ K^P \rightarrow 0 &\Leftrightarrow K_i^P \rightarrow 0 \forall i = 1, \dots, n. \end{aligned}$$

Proof. Let us first consider the case when $K^P \rightarrow \infty$. In the equilibrium of (9), the voltages satisfy by (11):

$$\begin{aligned} \lim_{K^P \rightarrow \infty} V &= \lim_{K^P \rightarrow \infty} (\mathcal{L}_R + K^P)^{-1} (K^P V^{\text{nom}} + I^{\text{inj}}) \\ &= \lim_{K^P \rightarrow \infty} (K^P)^{-1} (K^P V^{\text{nom}} + I^{\text{inj}}) = V^{\text{nom}}. \end{aligned}$$

By inserting the above expression for the voltages, the controlled injected currents are given by

$$\begin{aligned} \lim_{K^P \rightarrow \infty} u &= \lim_{K^P \rightarrow \infty} K^P (V^{\text{nom}} - V) \\ &= \lim_{K^P \rightarrow \infty} K^P \left(-(K^P)^{-1} I^{\text{inj}} \right) = -I^{\text{inj}}. \end{aligned}$$

Now consider the case when $K^P \rightarrow 0$. Since $(\mathcal{L}_R + K^P)$ is real and symmetric, any vector in \mathbb{R}^n can be expressed as a linear combination of its eigenvectors. Denote by (v_i, λ_i) the eigenvector and eigenvalue pair i of $(\mathcal{L}_R + K^P)$. Write

$$(K^P V^{\text{nom}} + I^{\text{inj}}) = \sum_{i=1}^n a_i v_i, \quad (13)$$

where $a_i, i = 1, \dots, n$ are real constants. The equilibrium of (9) implies that the voltages satisfy

$$\begin{aligned} \lim_{K^P \rightarrow 0} V &= \lim_{K^P \rightarrow 0} (\mathcal{L}_R + K^P)^{-1} (K^P V^{\text{nom}} + I^{\text{inj}}) \\ &= \lim_{K^P \rightarrow 0} (\mathcal{L}_R + K^P)^{-1} \sum_{i=1}^n a_i v_i \\ &= \lim_{K^P \rightarrow 0} \sum_{i=1}^n \frac{a_i}{\lambda_i} v_i = \frac{a_1}{\lambda_1} v_1, \end{aligned}$$

where λ_1 is the smallest eigenvalue of $(\mathcal{L}_R + K^P)$, which clearly satisfies $\lambda_1 \rightarrow 0^+$ as $K_i^P \rightarrow 0 \forall i = 1, \dots, n$. Hence the last equality in the above equation holds. By letting $K^P \rightarrow 0$ and premultiplying (13) with $v_1^T = 1/n \mathbf{1}_n$, we obtain $a_1 = (\frac{1}{n} \sum_{i=1}^n I_i^{\text{inj}})$ since the eigenvectors of $(\mathcal{L}_R + K^P)$ form an orthonormal basis of \mathbb{R}^n . Thus $\lim_{K^P \rightarrow 0} \lim_{t \rightarrow \infty} V(t) = \text{sgn} \left(\sum_{i=1}^n I_i^{\text{inj}} \right) \infty \mathbf{1}_n$. Finally the controlled injected currents are given by

$$\begin{aligned} \lim_{K^P \rightarrow 0} u &= \lim_{K^P \rightarrow 0} K^P (V^{\text{nom}} - V) \\ &= \lim_{K^P \rightarrow 0} K^P (V^{\text{nom}} - \frac{a_1}{\lambda_1} \mathbf{1}_n) = -\frac{a_1}{\lambda_1} K^P \mathbf{1}_n. \end{aligned}$$

By premultiplying (10) with $\mathbf{1}_n^T C^{-1}$ we obtain

$$\mathbf{1}_n^T K^P (V^{\text{nom}} - V) = -\mathbf{1}_n^T I^{\text{inj}},$$

which implies that

$$\frac{a_1}{\lambda_1} = \frac{\mathbf{1}_n^T I^{\text{inj}}}{\mathbf{1}_n^T K^P \mathbf{1}_n} = \left(\sum_{i=1}^n I_i^{\text{inj}} \right) / \left(\sum_{i=1}^n K_i^P \right),$$

which gives $u = u^*$ due to Lemma 2. \square

VI. DISTRIBUTED MTDC CONTROL

The shortcomings of the VDM control, as indicated in Theorem 4, motivate the development of novel controllers for MTDC networks. In this section we present three distributed controllers for MTDC networks, allowing for communication between HVDC buses. The use of a communication network allows for distributed controllers, all fulfilling Objective 1. The architectures of the controllers proposed later on in this section are illustrated in Figure 1.

A. Distributed averaging controller I

In this section we propose the following distributed controller for MTDC networks which allows for communication between the buses:

$$\begin{aligned} u_i &= K_i^P (\hat{V}_i - V_i) \\ \dot{\hat{V}}_i &= K_i^V (V_i^{\text{nom}} - V_i) \\ &\quad - \gamma \sum_{j \in \mathcal{N}_i} c_{ij} \left((\hat{V}_i - V_i) - (\hat{V}_j - V_j) \right), \end{aligned} \quad (14)$$

where $\gamma > 0$ is a constant, $K_i^P > 0, i = 1, \dots, n$, and

$$K_i^V = \begin{cases} K_1^V > 0 & \text{if } i = 1 \\ 0 & \text{otherwise.} \end{cases}$$




Figure 1: (a) shows the decentralized architecture of the voltage droop controller (VDM). (b) shows the distributed architecture of Controllers (I) and (III). (c) shows the architecture of Controller (II), with all-to-all communication.

This controller can be understood as a proportional control loop (consisting of the first line), and an integral control loop (consisting of the second line). The internal controller variables \hat{V}_i can be understood as reference values for the proportional control loops, regulated by the integral control loop. Bus $i = 1$, without loss of generality, acts as an integral voltage regulator. The first line of (I) ensures that the controlled injected currents are quickly adjusted after a change in the voltage. The parameter $c_{ij} = c_{ji} > 0$ is a constant, and \mathcal{N}_i denotes the set of buses which can communicate with bus i . The communication graph is assumed to be undirected, i.e., $j \in \mathcal{N}_i \Leftrightarrow i \in \mathcal{N}_j$. The second line ensures that the voltage is restored at bus 1 by integral action, and that the controlled injected currents converge to the optimal value, as proven later on. In vector-form, (I) can be written as

$$\begin{aligned} u &= K^P (\hat{V} - V) \\ \dot{\hat{V}} &= K^V (V_1^{\text{nom}} \mathbf{1}_n - V) - \gamma \mathcal{L}_c (\hat{V} - V), \end{aligned} \quad (14)$$

where K^P is defined as before, $K^V = \text{diag}([K_1^V, 0, \dots, 0])$, and \mathcal{L}_c is the weighted Laplacian matrix of the graph representing the communication topology, denoted \mathcal{G}_c , whose edge-weights are given by c_{ij} , and which is assumed to be connected. The following theorem shows that the proposed controller (I) has desirable properties which the droop controller (VDM) is lacking. It also gives sufficient conditions for which controller parameters stabilize the equilibrium of the closed-loop system.

Theorem 7. Consider an MTDC network described by (1), where the control input u_i is given by (I) and the injected currents I^{inj} are constant. The equilibrium of the closed-loop system is stable if

$$\begin{aligned} \frac{1}{2} \lambda_{\min} \left((K^P)^{-1} \mathcal{L}_R + \mathcal{L}_R (K^P)^{-1} \right) + 1 \\ + \frac{\gamma}{2} \lambda_{\min} \left(\mathcal{L}_c (K^P)^{-1} C + C (K^P)^{-1} \mathcal{L}_c \right) > 0 \end{aligned} \quad (15)$$

$$\lambda_{\min} \left(\mathcal{L}_c (K^P)^{-1} \mathcal{L}_R + \mathcal{L}_R (K^P)^{-1} \mathcal{L}_c \right) \geq 0. \quad (16)$$

Furthermore, $\lim_{t \rightarrow \infty} V_1(t) = V^{\text{nom}}$, and if $K^P = F^{-1}$ then $\lim_{t \rightarrow \infty} u(t) = u^*$. This implies that Objective 1 is satisfied given that $g_1 = 1$ and $g_i = 0$ for all $i \geq 2$.

Proof. The closed-loop dynamics of (2) with the controlled injected currents u given by (14) are given by

$$\begin{bmatrix} \dot{\hat{V}} \\ \dot{V} \end{bmatrix} = \underbrace{\begin{bmatrix} -\gamma \mathcal{L}_c & \gamma \mathcal{L}_c - K^V \\ EK^P & -E(\mathcal{L}_R + K^P) \end{bmatrix}}_{\triangleq A} \begin{bmatrix} \hat{V} \\ V \end{bmatrix} + \begin{bmatrix} K^V V^{\text{nom}} \mathbf{1}_n \\ CI^{\text{inj}} \end{bmatrix}. \quad (17)$$

The characteristic equation of A is given by

$$\begin{aligned} 0 &= \det(sI_{2n} - A) = \begin{vmatrix} sI_n + \gamma \mathcal{L}_c & -\gamma \mathcal{L}_c + K^V \\ -EK^P & sI_n + E(\mathcal{L}_R + K^P) \end{vmatrix} \\ &= \frac{|CK^P|}{|sI_n + \gamma \mathcal{L}_c|} \begin{vmatrix} sI_n + \gamma \mathcal{L}_c & -\gamma \mathcal{L}_c + K^V \\ -sI_n - \gamma \mathcal{L}_c & (sI_n + \gamma \mathcal{L}_c)(K^P)^{-1}C \\ & (sI_n + E(\mathcal{L}_R + K^P)) \end{vmatrix} \\ &= |CK^P| \left| (sI_n + \gamma \mathcal{L}_c)(K^P)^{-1}C(sI_n + E(\mathcal{L}_R + K^P)) \right. \\ &\quad \left. - \gamma \mathcal{L}_c + K^V \right| \\ &= |EK^P| \left| (\gamma \mathcal{L}_c (K^P)^{-1} \mathcal{L}_R + K^V) + s((K^P)^{-1} \mathcal{L}_R + I_n \right. \\ &\quad \left. + \gamma \mathcal{L}_c (K^P)^{-1} C) + s^2((K^P)^{-1} C) \right| \\ &\triangleq |EK^P| \det(Q(s)). \end{aligned}$$

This assumes that $|sI_n + \gamma \mathcal{L}_c| \neq 0$, however $|sI_n + \gamma \mathcal{L}_c| = 0$ implies $s = 0$ or $s \in \mathbb{C}^-$. By elementary column operations, A is shown to be full rank. This still implies that all solutions satisfy $s \in \mathbb{C}^-$. Now, the above equation has a solution only if $x^T Q(s)x = 0$ for some $x : \|x\|_2 = 1$. This condition gives the following equation

$$\begin{aligned} 0 &= \underbrace{x^T (\gamma \mathcal{L}_c (K^P)^{-1} \mathcal{L}_R + K^V) x}_{a_0} \\ &\quad + \underbrace{s x^T ((K^P)^{-1} \mathcal{L}_R + I_n + \gamma \mathcal{L}_c (K^P)^{-1} C) x}_{a_1} \\ &\quad + \underbrace{s^2 x^T ((K^P)^{-1} C) x}_{a_2}, \end{aligned}$$

which by the Routh-Hurwitz stability criterion has all solutions $s \in \mathbb{C}^-$ if and only if $a_i > 0$ for $i = 0, 1, 2$.

Clearly, $a_2 > 0$, since $((K^P)^{-1}C)$ is diagonal with positive elements. It is easily verified that $a_1 > 0$ if

$$\begin{aligned} & \frac{1}{2}\lambda_{\min} \left((K^P)^{-1}\mathcal{L}_R + \mathcal{L}_R(K^P)^{-1} \right) \\ & + \frac{\gamma}{2}\lambda_{\min} \left(\mathcal{L}_c(K^P)^{-1}C + C(K^P)^{-1}\mathcal{L}_c \right) + 1 > 0. \end{aligned}$$

Finally, clearly $x^T(\mathcal{L}_c(K^P)^{-1}\mathcal{L}_R)x \geq 0$ for any $x: \|x\|_2 = 1$ if and only if

$$\frac{1}{2}\lambda_{\min} \left(\mathcal{L}_c(K^P)^{-1}\mathcal{L}_R + \mathcal{L}_R(K^P)^{-1}\mathcal{L}_c \right) \geq 0.$$

Since the graphs corresponding to \mathcal{L}_R and \mathcal{L}_c are both assumed to be connected, the only x for which $x^T(\mathcal{L}_c(K^P)^{-1}\mathcal{L}_R)x = 0$ is $x = \frac{1}{\sqrt{n}}[1, \dots, 1]^T$. Given this $x = \frac{1}{\sqrt{n}}[1, \dots, 1]^T$, $x^TK^Vx = \frac{1}{n}K_1^V > 0$. Thus, $a_0 > 0$ gives that the above inequality holds. Thus, under assumptions (15)–(16), A is Hurwitz, and thus the equilibrium of the closed-loop system is stable.

Now consider the equilibrium of (17). Premultiplying the first n rows with 1_n^T yields $0 = 1_n^TK^V(V^{\text{nom}}1_n - V) = K_1^V(V^{\text{nom}} - V_1)$. Clearly this minimizes (5), with the minimal value 0. Inserting this back to the first n rows of (17) yields $0 = \mathcal{L}_c(V - \hat{V})$, implying that $(V - \hat{V}) = k1_n$. It should be noted here that if $K_i^V > 0$ for at least one $i \geq 2$, then the first n rows of (17) do not imply $(V - \hat{V}) = k1_n$ in general. Inserting the relation $(V - \hat{V}) = k1_n$ in (14) gives $u = K^P(V - \hat{V}) = \lambda K^P1_n$. Setting $K^P = F^{-1}$, (3)–(4) are satisfied by Lemma 2. \square

Remark 5. For sufficiently uniformly large K^P , and sufficiently small γ , the condition (15) is fulfilled.

Corollary 8. A sufficient condition for when (16) is fulfilled, is that $\mathcal{L}_c = \mathcal{L}_R$, i.e., the topology of the communication network is identical to the topology of the power transmission lines and the edge weights of the graphs are identical.

B. Distributed averaging controller II

While the controller (I) is clearly distributed, it has poor redundancy due to a specific HVDC bus dedicated for voltage measurement. Should the dedicated bus fail, the voltage of bus 1 will not converge to the reference voltage asymptotically. To improve the redundancy of (I), we propose the following controller:

$$\begin{aligned} u_i &= K_i^P(\hat{V}_i - V_i) \\ \dot{\hat{V}}_i &= k^V \sum_{i \in \mathcal{V}} (V_i^{\text{nom}} - V_i) \\ & - \gamma \sum_{j \in \mathcal{N}_i} c_{ij} \left((\hat{V}_i - V_i) - (\hat{V}_j - V_j) \right), \quad (\text{II}) \end{aligned}$$

where $\gamma > 0$ and $k^V > 0$ are constants. This controller can as (I) be interpreted as a fast proportional control loop (consisting of the first line), and a slower integral control loop (consisting of the second and third lines). In contrast to (I) however, every bus implementing (II) requires voltage measurements from all buses of the MTDC system. Thus,

controller (II) requires a complete communication graph. As long as the internal controller dynamics of \hat{V} are sufficiently slow (e.g., by choosing k^V sufficiently small), this is a reasonable assumption provided that a connected communication network exists. In vector-form, (II) can be written as

$$\begin{aligned} u &= K^P(\hat{V} - V) \\ \dot{\hat{V}} &= k^V 1_{n \times n}(V^{\text{nom}} - V) - \gamma \mathcal{L}_c(\hat{V} - V), \quad (\text{18}) \end{aligned}$$

where K^P is defined as before, $V^{\text{nom}} = [V_1^{\text{nom}}, \dots, V_n^{\text{nom}}]^T$ and \mathcal{L}_c is the weighted Laplacian matrix of the graph representing the communication topology, denoted \mathcal{G}_c , whose edge-weights are given by c_{ij} , and which is assumed to be connected. The following theorem is analogous to Theorem 7, and gives sufficient conditions for which controller parameters result in a stable equilibrium of the closed-loop system.

Theorem 9. Consider an MTDC network described by (1), where the control input u_i is given by (II) and the injected currents I^{inj} are constant. The equilibrium of the closed-loop system is stable if (15) and (16) are satisfied. If furthermore $K^P = F^{-1}$, then $\lim_{t \rightarrow \infty} u(t) = u^*$, and if $G = I_n$, where $G = \text{diag}([g_1, \dots, g_n])$, (5) is minimized. This implies that Objectives 1 is satisfied.

Proof. The proof is analogous to the proof of Theorem 7. Since $x^T 1_{n \times n}x = (1_n^T x)^T(1_n^T x) \geq 0$, $1_{n \times n} \geq 0$, implying that the term a_0 is positive if

$$\frac{1}{2}\lambda_{\min} \left(\mathcal{L}_c(K^P)^{-1}\mathcal{L}_R + \mathcal{L}_R(K^P)^{-1}\mathcal{L}_c \right) \geq 0.$$

Thus the matrix A is Hurwitz whenever (15) and (16) are satisfied. The equilibrium of the closed-loop system implies that $1_n^T(V^{\text{nom}} - V) = 0$. Thus, by Lemma 3, Equation (5) is minimized. The remainder of the proof is identical to the proof of Theorem 7, and is omitted. \square

Remark 6. For sufficiently uniformly large K^P , and sufficiently small γ , the condition (16) is fulfilled.

C. Distributed averaging controller III

While the assumption that the voltage measurements can be communicated instantaneously through the whole MTDC network is reasonable for small networks or slow internal controller dynamics, the assumption might be unreasonable for larger networks. To overcome this potential issue, a novel controller is proposed. The proposed controller takes inspiration from the control algorithms given in [3], [5], [24], and is given by

$$\begin{aligned} u_i &= -K_i^P(V_i - \hat{V}_i - \bar{V}_i) \\ \dot{\hat{V}}_i &= -\gamma \sum_{j \in \mathcal{N}_i} c_{ij} \left((\hat{V}_i + \bar{V}_i - V_i) - (\hat{V}_j + \bar{V}_j - V_j) \right) \\ \dot{\bar{V}}_i &= -K_i^V(V_i - V_i^{\text{nom}}) - \delta \sum_{j \in \mathcal{N}_i} c_{ij}(\bar{V}_i - \bar{V}_j). \quad (\text{III}) \end{aligned}$$

The first line of the controller (III) can be interpreted as a proportional controller, whose reference value is controlled by the remaining two lines. The second line ensures that the

weighted current injections converge to the identical optimal value through a consensus-filter. The third line is a distributed secondary voltage controller, where each bus measures the voltage and updates the reference value through a consensus-filter. In vector form, (III) can be written as

$$\begin{aligned} u &= -K^P(V - \hat{V} - \bar{V}) \\ \dot{\hat{V}} &= -\gamma\mathcal{L}_c(\hat{V} + \bar{V} - V) \\ \dot{\bar{V}} &= -K^V(V - V^{\text{nom}}) - \delta\mathcal{L}_c\bar{V}, \end{aligned} \quad (19)$$

where $K^P = \text{diag}([K_1^P, \dots, K_n^P])$, $K^V = \text{diag}([K_1^V, \dots, K_n^V])$, $V^{\text{nom}} = [V_1^{\text{nom}}, \dots, V_n^{\text{nom}}]^T$ and \mathcal{L}_c is the weighted Laplacian matrix of the graph representing the communication topology, denoted \mathcal{G}_c , whose edge-weights are given by c_{ij} , and which is assumed to be connected. Substituting the controller (19) in the system dynamics (2), yields

$$\begin{aligned} \begin{bmatrix} \dot{\bar{V}} \\ \dot{\hat{V}} \\ \dot{V} \end{bmatrix} &= \underbrace{\begin{bmatrix} -\delta\mathcal{L}_c & 0_{n \times n} & -K^V \\ -\gamma\mathcal{L}_c & -\gamma\mathcal{L}_c & \gamma\mathcal{L}_c \\ EK^P & EK^P & -E(\mathcal{L}_R + K^P) \end{bmatrix}}_{\triangleq A} \begin{bmatrix} \bar{V} \\ \hat{V} \\ V \end{bmatrix} \\ &+ \underbrace{\begin{bmatrix} K^V V^{\text{nom}} \\ 0_n \\ ET^{\text{inj}} \end{bmatrix}}_{\triangleq b}. \end{aligned} \quad (20)$$

The following theorem characterizes when the controller (I) stabilizes the equilibrium of (1), and shows that it has some desirable properties.

Theorem 10. *Consider an MTDC network described by (1), where the control input u_i is given by (III) and the injected currents I^{inj} are constant. If all eigenvalues of A , except the one eigenvalue which always equals 0, lie in \mathbb{C}^- , $K^P = F^{-1}$ and $K^V = G$, where $G = \text{diag}([g_1, \dots, g_n])$, then Objective 1 is satisfied given any non-negative constants g_i , $i = 1, \dots, n$.*

Proof. It is easily shown that A as defined in (20), has one eigenvalue equal to 0. The right-eigenvector of A corresponding to the zero eigenvalue is $v_1 = 1/\sqrt{2n}[1_n^T, -1_n^T, 0_n^T]^T$. Since b as defined in (20), is not parallel to v_1 , $\lim_{t \rightarrow \infty} [\bar{V}(t), \hat{V}(t), V(t)]$ exists and is finite, by the assumption that all other eigenvalues lie in \mathbb{C}^- . Hence, we consider any stationary solution of (20)

$$\begin{bmatrix} \delta\mathcal{L}_c & 0_{n \times n} & K^V \\ \gamma\mathcal{L}_c & \gamma\mathcal{L}_c & -\gamma\mathcal{L}_c \\ -K^P & -K^P & (\mathcal{L}_R + K^P) \end{bmatrix} \begin{bmatrix} \bar{V} \\ \hat{V} \\ V \end{bmatrix} = \begin{bmatrix} K^V V^{\text{nom}} \\ 0_n \\ I^{\text{inj}} \end{bmatrix}. \quad (21)$$

Premultiplying (21) with $[1_n^T, 0_n^T, 0_n^T]$ yields

$$1_n^T K^V (V^{\text{nom}} - V) = \sum_{i=1}^n K_i^V (V_i^{\text{nom}} - V_i^{\text{nom}}) = 0,$$

which by Lemma 3 implies that Equation (5) is minimized. The $n+1$ -th to $2n$ -th lines of (21) imply $\mathcal{L}_c(\bar{V} + \hat{V} - V) =$

$0_n \Rightarrow (\bar{V} + \hat{V} - V) = k_1 1_n \Rightarrow u = K^P(\bar{V} + \hat{V} - V) = k_1 K^P 1_n$. By Lemma 2, (3)–(4) are satisfied. \square

Note that Controller (III) is the only controller among the presented controllers which minimizes Equation (5), for any a priori given constants g_i , $i = 1, \dots, n$. Controllers (I) and (II) minimize Equation (5), but for specific values of g_i , $i = 1, \dots, n$. While Theorem 10 establishes an exact condition when the distributed controller (III) stabilizes the equilibrium of the MTDC system (1), it does not give any insight in how to choose the controller parameters to stabilize the equilibrium. The following theorem gives a sufficient stability condition for a special case.

Theorem 11. *Assume that $\mathcal{L}_c = \mathcal{L}_R$, i.e. that the topology of the communication network is identical to the topology of the MTDC system. Assume furthermore that $K^P = k^P I_n$, i.e. the controller gains are equal. Then all eigenvalues of A except the zero eigenvalue lie in \mathbb{C}^- if*

$$\frac{\gamma + \delta}{2k^P} \lambda_{\min}(\mathcal{L}_R C + C \mathcal{L}_R) + 1 > 0 \quad (22)$$

$$\frac{\gamma\delta}{2k^P} \lambda_{\min}(\mathcal{L}_R^2 C + C \mathcal{L}_R^2) + \min_i K_i^V > 0 \quad (23)$$

$$\lambda_{\max}(\mathcal{L}_R^3) \frac{\gamma\delta}{k^P} > 0$$

$$\leq \left(\frac{\gamma + \delta}{2k^P} \lambda_{\min}(\mathcal{L}_R C + C \mathcal{L}_R) + 1 \right) \times \left(\frac{\gamma\delta}{2k^P} \lambda_{\min}(\mathcal{L}_R^2 C + C \mathcal{L}_R^2) + \min_i K_i^V \right) \quad (24)$$

Proof. Following similar steps as the proof of Theorem 7, one obtains after some tedious matrix manipulations that (20) is stable if the following equation has solutions $s \in \mathbb{C}^-$:

$$\begin{aligned} 0 &= x^T Q(s)x = \underbrace{\frac{\gamma\delta}{k^P} x^T \mathcal{L}_R^3 x}_{a_0} \\ &+ s x^T \underbrace{\left[\frac{\delta + \gamma}{k^P} \mathcal{L}_R^2 + \delta \mathcal{L}_R + \frac{\gamma\delta}{k^P} \mathcal{L}_R^2 C + K^V \right] x}_{a_1} \\ &+ s^2 x^T \underbrace{\left[\frac{1}{k^P} \mathcal{L}_R + I_n + \frac{\gamma + \delta}{k^P} \mathcal{L}_R C \right] x}_{a_2} + s^3 \underbrace{\frac{1}{k^P} x^T C x}_{a_3}. \end{aligned} \quad (25)$$

Clearly (25) has one solution $s = 0$ for $x = \frac{a}{\sqrt{n}}[1, \dots, 1]^T$, since this implies that $a_0 = 0$. The remaining solutions are stable if and only if the polynomial $a_1 + s a_2 + s^2 a_3 = 0$ is Hurwitz, which is equivalent to $a_i > 0$ for $i = 1, 2, 3$ by the Routh-Hurwitz stability criterion. For $x \neq \frac{a}{\sqrt{n}}[1, \dots, 1]^T$, we have that $a_0 > 0$, and thus $s = 0$ cannot be a solution of (25). By the Routh-Hurwitz stability criterion, (25) has stable solutions if and only if $a_i > 0$ for $i = 0, 1, 2, 3$ and $a_0 a_3 < a_1 a_2$. Since this condition implies that $a_i > 0$ for $i = 1, 2, 3$, there is no need to check this second condition explicitly. Clearly $a_3 > 0$ since $(K^P)^{-1}$ and C are diagonal with positive elements. It is easily verified that $a_2 > 0$ if (22) holds, since $\mathcal{L}_R \geq 0$. Similarly, $a_1 > 0$ if (23) holds, since also $\mathcal{L}_R^2 \geq 0$ and $x^T K^V x \geq \min_i K_i^V$. In order to assure

Table I: System parameter values used in the simulation.

Parameter	Value [Unit]
C_i	$57\mu\text{F}$
R_{ij}	3.7Ω

Table II: Controller parameter values used in the simulation.

Parameter/Controller	I	II	III
k^P	$10 \Omega^{-1}$	$10 \Omega^{-1}$	$0.5 \Omega^{-1}$
k^V	10	5	2.5
γ	20	15	3
δ	-	-	2

that $a_0 a_3 < a_1 a_2$, we need furthermore to upper bound $a_0 a_3$. The following bound is easily verified

$$a_0 a_3 < \lambda_{\max} \left(\mathcal{L}_R^3 \right) \frac{\gamma \delta}{k^P} \max_i C_i.$$

Using this, together with the lower bounds on a_1 and a_2 , we obtain that (24) is a sufficient condition for $a_0 a_3 < a_1 a_2$. \square

Remark 7. For sufficiently small γ and δ , and sufficiently large k^P and $\min_i K_i^V$, the inequalities (22)–(24) hold, thus always making it possible to choose stabilizing controller gains.

VII. SIMULATIONS

Simulations of an MTDC system were conducted using MATLAB. The MTDC was modelled by (1), with u_i given by the distributed controllers (I), (II) and (III), respectively. The topology of the MTDC system is assumed to be as illustrated in Figure ???. The system parameter values are obtained from [14], where the inductances of the DC lines are neglected, and the capacitances of the DC lines are assumed to be located at the converters. The system parameter values are assumed to be identical for all converters, and are given in Table I. The controller parameters are also assumed to be uniform, i.e., $K_i^P = k_p$, $K_i^V = k^V$ for $i = 1, 2, 3, 4$, and their numerical values are given in Table II. Due to the communication of controller variables, a constant delay of 500 ms is assumed. The delay only affects remote information, so that, e.g., the first line of the controllers (I), (II) and (III) remain delay-free.

The communication gains were set to $c_{ij} = R_{ij}^{-1}$ S for all $(i, j) \in \mathcal{E}$ and for all controllers. The injected currents are assumed to be initially given by $I^{\text{inj}} = [300, 200, -100, -400]^T$ A, and the system is allowed to converge to its equilibrium. Since the injected currents satisfy $I_i^{\text{inj}} = 0$, $u_i = 0$ for $i = 1, 2, 3, 4$ by Theorem 7. Then, at time $t = 0$, the injected currents are changed to $I^{\text{inj}} = [300, 200, -300, -400]^T$ A. The step responses of the voltages V_i and the controlled injected currents u_i are shown in Figure 2. The conservative voltage bounds implied by Lemma 1, are indicated by the two dashed lines. We note that the controlled injected currents u_i converge to their optimal values, and that the voltages remain within the bounds.


VIII. DISCUSSION AND CONCLUSIONS

In this paper we have studied VDM for MTDC systems, and highlighted some of its weaknesses. To overcome some of its disadvantages, three distributed controllers for MTDC systems were proposed. We showed that under certain conditions, there exist controller parameters such that the equilibria of the closed-loop systems are stabilized. In particular, a sufficient stability condition is that the graphs of the physical MTDC network and the communication network are identical, including their edge weights. We have shown that the proposed controllers are able to control the voltage levels of the DC buses close towards the nominal voltages, while simultaneously minimizing a quadratic cost function of the current injections. The proposed controllers were tested on a four-bus MTDC network by simulation, demonstrating their effectiveness.


This paper lays the foundation for distributed control strategies for hybrid AC and MTDC systems. Future work will in addition to the voltage dynamics of the MTDC system, also consider the dynamics of connected AC systems. Interconnecting multiple asynchronous AC systems also enables novel control applications, for example automatic sharing of primary and secondary frequency control reserves. Preliminary results on decentralized cooperative AC frequency control by an MTDC grid have been presented in [6].

REFERENCES


- [1] S. Anand, B. G. Fernandes, and M. Guerrero. Distributed control to ensure proportional load sharing and improve voltage regulation in low-voltage DC microgrids. *IEEE Transactions on Power Electronics*, 28(4):1900–1913, April 2013.
- [2] M. Andreasson, D. V. Dimarogonas, H. Sandberg, and K. H. Johansson. Control of MTDC transmission systems under local information. In *Conference on Decision and Control*, 2014.
- [3] M. Andreasson, D. V. Dimarogonas, H. Sandberg, and K. H. Johansson. Distributed PI-control with applications to power systems frequency control. In *American Control Conference*, pages 3183–3188, June 2014.
- [4] M. Andreasson, D.V. Dimarogonas, H. Sandberg, and K.H. Johansson. Distributed control of networked dynamical systems: Static feedback, integral action and consensus. *Automatic Control, IEEE Transactions on*, 59(7):1750–1764, July 2014.
- [5] M. Andreasson, M. Nazari, D. V. Dimarogonas, H. Sandberg, K. H. Johansson, and M. Ghandhari. Distributed voltage and current control of multi-terminal high-voltage direct current transmission systems. In *IFAC World Congress*, pages 11910–11916, Aug. 2014.
- [6] M. Andreasson, R. Wiget, D. V. Dimarogonas, K. H. Johansson, and G. Andersson. Distributed primary frequency control through multi-terminal HVDC transmission systems. *arXiv:1409.8013*, 2014.
- [7] P. Bresesti, W. L. Kling, R. L. Hendriks, and R. Vailati. HVDC connection of offshore wind farms to the transmission system. *Energy Conversion, IEEE Transactions on*, 22(1):37–43, 2007.
- [8] P. Bresesti, W.L. Kling, R.L. Hendriks, and R. Vailati. HVDC connection of offshore wind farms to the transmission system. *Energy Conversion, IEEE Transactions on*, 22(1):37–43, March 2007.
- [9] J. Dai, Y. Phulpin, A. Sarlette, and D. Ernst. Impact of delays on a consensus-based primary frequency control scheme for AC systems connected by a multi-terminal HVDC grid. In *Bulk Power System Dynamics and Control (iREP)-VIII (iREP)*, 2010 *iREP Symposium*, pages 1–9. IEEE, 2010.
- [10] J. Dai, Y. Phulpin, A. Sarlette, and D. Ernst. Voltage control in an HVDC system to share primary frequency reserves between non-synchronous areas. In *Proc. 17th power systems computation conference*, 2011.




(I.a) Controller I, bus voltages




(I.b) Controller I, controlled injected currents




(II.a) Controller II, bus voltages



(II.b) Controller II, controlled injected currents



(III.a) Controller III, bus voltages



(III.b) Controller III, controlled injected currents

Figure 2: The figures show the voltages V_i and the controlled injected currents u_i , respectively. The system model is given by (1), and u_i is given by the distributed controllers (I), (II) and (III), respectively. We note that all controllers demonstrate reasonable performance. Controller (III) has the advantage of being fully distributed, while Controller (I) requires a dedicated voltage measurement bus, and Controller (II) requires a complete communication network.

- [11] F. Dörfler, J. Simpson-Porco, and F. Bullo. Breaking the hierarchy: Distributed control & economic optimality in microgrids. *arXiv preprint arXiv:1401.1767*, 2014.
- [12] T. Haileselassie, K. Uhlen, and T. Undeland. Control of multiterminal HVDC transmission for offshore wind energy. In *Nordic Wind Power Conference*, pages 10–11, 2009.
- [13] B.K. Johnson, R.H. Lasseter, F.L. Alvarado, and R. Adapa. Expandable multiterminal dc systems based on voltage droop. *Power Delivery, IEEE Transactions on*, 8(4):1926–1932, 1993.
- [14] D. Jovicic, L. Lamont, and L. Xu. VSC transmission model for analytical studies. In *IEEE Power Engineering Society General Meeting*, volume 3, 2003.
- [15] P. Kundur. *Power System Stability and Control*. The EPRI Power System Engineering. McGraw-Hill Companies, Incorporated, 1994.
- [16] N. Li, L. Chen, C. Zhao, and S. H. Low. Connecting automatic generation control and economic dispatch from an optimization view. In *American Control Conference*, 2014.
- [17] X. Lu, J.M. Guerrero, K. Sun, and J.C. Vasquez. An improved droop control method for DC microgrids based on low bandwidth communication with DC bus voltage restoration and enhanced current sharing accuracy. *IEEE Transactions on Power Electronics*, 29(4):1800–1812, April 2014.
- [18] E. Mallada, C. Zhao, and S. H. Low. Optimal load-side control for frequency regulation in smart grids. *arXiv:1410.2931*, 2014.
- [19] T. Nakajima and S. Irokawa. A control system for HVDC transmission by voltage sourced converters. In *Power Engineering Society Summer Meeting, 1999. IEEE*, volume 2, pages 1113–1119 vol.2, 1999.
- [20] V. Nasirian, A. Davoudi, F.L. Lewis, and J.M. Guerrero. Distributed adaptive droop control for DC distribution systems. *IEEE Transactions on Energy Conversion*, 29(4):944–956, Dec 2014.
- [21] K. R. Padiyar. *HVDC power transmission systems: technology and system interactions*. New Age International, 1990.
- [22] A. Sarlette, J. Dai, Y. Phulpin, and D. Ernst. Cooperative frequency control with a multi-terminal high-voltage DC network. *Automatica*, 48(12):3128–3134, 2012.
- [23] B. Silva, C. L. Moreira, L. Seca, Y. Phulpin, and J. A. Peas Lopes. Provision of inertial and primary frequency control services using offshore multiterminal HVDC networks. *Sustainable Energy, IEEE Transactions on*, 3(4):800–808, 2012.
- [24] J. W. Simpson-Porco, F. Dörfler, and F. Bullo. Synchronization and power sharing for droop-controlled inverters in islanded microgrids. *Automatica*, Nov, 2012.
- [25] D. Van Hertem and M. Ghandhari. Multi-terminal VSC HVDC for the european supergrid: Obstacles. *Renewable and Sustainable Energy Reviews*, 14(9):3156–3163, 2010.